



**NOTE:**

PROVIDE 6" MINIMUM CRUSHED STONE CRADLE UNDER PIPE AND APPURTENANCES IN ROCK AREAS AND WHERE REQUIRED BY TRENCH AND SOIL CONDITIONS.

## BLOW-OFF HYDRANT

SNIEDZE ASSOCIATES, CONSULTING ENGINEERS  
CANANDAIGUA, NEW YORK

SCALE: 3/8" = 1'-0"

MAY 2007

WS-7-1