



NOTE:

1. PROVIDE POLYFOAM INSULATING BLANKET AND DRAPE IT OVER METER AND SETTING.
2. USE PIT FOR INDIVIDUAL SERVICES LONGER THAN 250 FEET FROM WATER MAIN.
3. USE PIT FOR ALL NEW CONSTRUCTION THAT DOES NOT HAVE A BASEMENT OR CRAWL SPACE.

PLASTIC PIT FOR WATER METER

**SNIEDZE ASSOCIATES, CONSULTING ENGINEERS
CANANDAIGUA, NEW YORK**

SCALE: 1 1/2" = 1'-0"

MAY 2007

WS-10