

WATER MAIN / SEWER CROSSING DETAIL

CONDITION	SCHEMATIC	REQUIREMENTS
I WATER LINE ABOVE SEWER LINE		A) WATER LINE AND SEWER LINE PIPE LENGTHS TO BE CENTERED AT CROSSING. EACH LENGTH OF PIPE TO BE 10 FT. MINIMUM.
II WATER LINE ABOVE SEWER LINE		A) WATER LINE AND SEWER LINE PIPE LENGTHS TO BE CENTERED AT CROSSING. EACH LENGTH OF PIPE TO BE 10 FT. MINIMUM. B) WHEN BOTH WATER LINE AND SEWER LINE ARE NEW, SLEEVE SEWER LINE WITH STEEL CASING FOR 10 FT. EACH SIDE OF CROSSING. -OR- WHEN ONE LINE IS EXISTING, SLEEVE PIPE BEING INSTALLED WITH STEEL CASING FOR 10 FT. EACH SIDE OF CROSSING.
III SEWER LINE ABOVE WATER LINE		A) WATER LINE AND SEWER LINE PIPE LENGTHS TO BE CENTERED AT CROSSING. EACH LENGTH OF PIPE TO BE 10 FT. MINIMUM. B) SLEEVE SEWER LINE WITH "STEEL CASING FOR 10FT." EACH SIDE OF CROSSING. C) PROVIDE CRADLE OF CONCRETE OR CRUSHER RUN STONE (SEE TRENCH SECTION DETAIL BELOW) FOR WATER LINE AND SEWER LINE FOR 10 FT. EACH SIDE OF CROSSING.
<u>NOTES</u>		
WL (WATER LINE) SL (SEWER LINE, SANITARY OR STORM) D (OUTSIDE DIAMETER OF PIPE)		
IN NO CASE SHALL PIPES BE CLOSER THAN 12" INCHES APART. DISTANCES ARE MEASURED BETWEEN OUTSIDES OF PIPE.		

WATER MAIN / SEWER CROSSING DETAIL

SNIEDZE ASSOCIATES, CONSULTING ENGINEERS
CANANDAIGUA, NEW YORK

NOT TO SCALE

MAY 2007

WS-3