



**NOTE:**

1. LOCK-TYPE JOINTS SHALL BE USED
2. ALL HYDRANT WEEP HOLES THAT ARE BELOW MEAN HIGH GROUNDWATER LEVEL SHALL BE PLUGGED. THE HYDRANTS WITH PLUGGED WEEP HOLES SHALL BE SO LABELED OR TAGGED.
3. PROVIDE HYDRANT BARREL EXTENSIONS FOR HYDRANTS LOCATED IN EMBANKMENTS

## HYDRANT UNIT

**SNIEDZE ASSOCIATES, CONSULTING ENGINEERS  
CANANDAIGUA, NEW YORK**

**SCALE: 3/8" = 1'-0"**

**MAY 2007**

**WS-5**