



NOTE:

PROVIDE 6" MINIMUM CRUSHED STONE CRADLE UNDER PIPE AND APPURTENANCES IN ROCK AREAS AND WHERE REQUIRED BY TRENCH AND SOIL CONDITIONS.

LINE VALVE

SNIEDZE ASSOCIATES, CONSULTING ENGINEERS
CANANDAIGUA, NEW YORK

SCALE: 3/8" = 1'-0"

MAY 2007

WS-6-1