



NOTE:

IF THIS TAP IS NOT TO BE USED FOR A WATER SERVICE, THE CONTRACTOR MUST REMOVE THE CORPORATION AND INSERT A BRASS PLUG IN THE MAIN.

SAMPLING & DISINFECTION TAP

SNIEDZE ASSOCIATES, CONSULTING ENGINEERS
CANANDAIGUA, NEW YORK

SCALE: 3/8" = 1'-0"

MAY 2007

WS-9